

NAGAR SEVA SADAN, BHUJ

Dr. Jayant Khatri Marg, Bhuj - Kutch

No. BNP/Fire/personally/21

Dt. 11/06/2021

To
S.S.G.M. School,
English Medium,
Nakhatrana Highway Road,
Mankuva - Kutch.

Sub: Issue of Fire N.O.C.

With reference to above, your application dtd. 07/06/2021 in subject matter, while inspecting in person, you have installed fire extinguisher /fire system at different places, considering this, Fire N.O.C. is issued with following condition.

Conditions:-

- 1) Implementation of Gujarat Fire Safety Act-2013 should be enforcing by 2016.
- 2) Electrical component and wiring must not be in open or loose..
- 3) Any accident, loss etc. management will be responsible.
- 4) Gas cylinder stock and inflammable items should be kept in tuition classis/ school.
- 5) Permission for Hotel/School/Restaurant/Tuition etc. should be obtain from competent officer.
- 6) Fire instruments should be maintain in running condition.
- 7) **EXIT/door** should not be blockage with any goods and Exit Sign board should be place.
- 8) Accident claim policy for concern property/classes should be obtain.
- 9) During Re-inspection, if electric loose wire trace out, N.O.C. granted will be cancelled with immediate effect.
- 10) During emergency in tuition classes, proper parking slot should be available to enter emergency vehicle.
- 11) This N.O.C. issued in respect of fire safety, therefore any misappropriation in construction, you will be responsible for the decision taken by Nagarpalika/BHADA office/Govt.
- 12) To maintain number of students in classes as per National Building Code 2016.
- 13) You have to trained student by providing demonstration of fire safety awareness.
- 14) Any religious/social/family function in tuition classes / school, fire cracker / balloon / inflammable material cannot be use.
- 15) When employee of Bhuj Nagarpalika visit for checking then it is your responsibility to show him N.O.C., and if N.O.C. not produce it will be presume that you have not obtained NOC, then you will be responsible for any action taken in this behalf.

This N.O.C. will be valid for the period from **11/06/2021 to 10/06/2022**, thereafter said N.O.C. have to renew. Any breach of above conditions, Fire N.O.C. shall be treated cancelled.

TRANSLATED BY**KHITISH M. PARMAR**

Translator / Petition Writer

3, Capital Plaza,

Manadev Gate, BHUJ

KUTCH - 370 001, INDIA

ROUND SEAL
OF FIRE &
EMERGENCY
SERVICES,
BHUJ
NAGARPALIKA

*illegible***Fire Officer****Bhuj Nagarpalika, Bhuj**